

BLOCK WATER TESTING LABORATORY, KHANNA
DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
Water Supply & Sanitation Division, Court Complex, Samadhi Road, Khanna, Dist. Ludhiana

bwtlkhanha@gmail.com

To,

Delhi Public School
Khanna


No.: BWTLKHA/2627/00173 Dated : 15/10/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DPSK/26/7057 Dated: 13/10/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 13/10/2026. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Khanna

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Khanna

BLOCK WATER TESTING LABORATORY, KHANNA
DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
 Water Supply & Sanitation Division, Court Complex, Samadhi Road, Khanna, Dist. Ludhiana

bwtlkhanna@gmail.com

TEST REPORT

Name & Address of Customer : Delhi Public School Khanna		Customer Reference No.	No : DPSK/26/7057 Dated : 13/10/2026
		Sample Submitted by	Lovepreet Singh
		Date of Sample Receipt	13/10/2026
		Analysis Starting Date	13/10/2026
		Analysis completion Date	14/10/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	NABLDWT0049426192F	Sample Type :	Water
Test Report No.:	BWTLKHA/2627/00173	Date of Issue :	15/10/2026
Registration no.:	BWTLKHA/REG2627/00760	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Delhi Public School, NH-1,G.T Road, Ikolahi Khanna / NA
Village :	Ikolahi	Habitation :	Ikolahi
Block:	Khanna	District :	Ludhiana
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.02	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	Total Dissolved Solids	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Total Alkalinity (CaCO ₃)	24	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Total Hardness (CaCO ₃)	76	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	16	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	9	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	16	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results relate to the sample tested as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Vijay Passi

Vijay Passi
 Chemist/Analyst
 Authorized Signatory
 For,Block Water Testing Laboratory
 Khanna

----- End of the Test Report -----